

VOC Content Test Certificate

Tuesday, October 1st, 2013

Manufacturer: Sealants Australasia Pty Ltd (U4/52 Vinnicombe Drive, Canning Vale WA 6155)

Sample Description: SA Silicone N-10 Silicone Sealant

Date Tested: September 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	SA Silicone N-10 Silicone Sealant
Architectural Sealants 250 grams per Litre as VOC content per material	<31 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130920