

VOC Content Test Certificate

Tuesday, October 1st, 2013

Manufacturer: Sealants Australasia Pty Ltd (U4/52 Vinnicombe Drive, Canning Vale WA 6155)

Sample Description: SA Plumbers Silicone Sealant

Date Tested: September 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">SA Plumbers Silicone Sealant</p>
<p align="center">Architectural Sealants</p> <p align="center">250 grams per Litre as VOC content per material</p>	<p align="center"><52 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130920